

Filing Receipt

Received - 2022-01-13 10:32:54 AM Control Number - 52667 ItemNumber - 34



Project No. 52667 Compliance Report

This report was prepared by Bandera Electric Cooperative, Inc. (BEC) to comply with PUCT Project No. 52667 regarding the Filing of Attestations Demonstrating Compliance with HB 4150.

Report Date	01/04/2022
Entity	Bandera Electric Cooperative, Inc.
Entity Type	Transmission and Distribution Service Provider
Lake listed in PURA § 38.004(b) in Bandera EC Service Area	(109) Medina Lake (56) Diversion Lake
County of Lake(s) and Distribution Line(s)	Bandera County Medina County

Line and Compliance Information

Line Identifier	Compliance with NESC ANSI(c)(2) Rule 232	Compliance Confirmation Date	Notes
Medina Lake Substation 3 Feeder 1, 2, 3, and 4	Yes	08/12/2020	Existing Structures/Spans were surveyed and verified to be in compliance with NESC ANSI(c)(2) Rule 232.
Medina Lake Substation 3 Feeder 1, 2, 3, and 4	Yes	12/31/2021	Existing Structures/Spans on the surveyed feeders not in compliance with NESC ANSI(c)(2) Rule 232 were identified, documented, and brought into compliance with NESC ANSI(c)(2) Rule 232 by changing pole structures, removing and rerouting lines, and by performing framing changes.

PROJECT NO. 52667

FILING OF ATTESTATION DEMONSTRATING COMPLIANCE WITH HB 4150 AFFIDAVIT OF COOPERATIVE OFFICER FOR BANDERA ELECTRIC COOPERATIVE, INC. FILED PURSUANT TO SECTION 6 HOUSE BILL 4150

STATE OF TEXAS § COUNTY OF BANDERA §

BEFORE ME, the undersigned authority, on this day personally appeared, and who, after being duly sworn, stated on his or her oath he or she is entitled to make this Affidavit, and that the statements contained below are true and correct.

I, William Hetherington, swear or affirm that as an Electric Cooperative operating in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system, confirms the following:

- Bandera Electric Cooperative, Inc. (BEC) operates a transmission and distribution utility system in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system;
- BEC owns distribution lines over (109) Medina Lake and (56) Diversion Lake, which are listed in PURA § 38.004(b). BEC has no transmission lines over any lakes listed in PURA § 38.004(b).
- The report prepared by BEC, titled Project No. 52667 Compliance Report, certifies that these distribution lines meet the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).

Chief Executive Officer,

Bandera Electric Coóperative, Inc.

{Signature of Officer of the Cooperative}

Sworn and subscribed before me on this 1240 day of January

COLLEEN DAVIS

My Notary ID # 120475483 Expires April 5, 2024

Notary Public in and for the State of Texas

(Must be notarized by a notary public in and for the State of Texas